

LGAI

LGAI Technological Center, S.A.
Campus UAB s/n
Apartado de Correos 18
E - 08193 Bellaterra (Barcelona)
T +34 93 567 20 00
F +34 93 567 20 01
www.appluslaboratories.com



Bellaterra, 9th October, 2019

LGAI Technological Center, S.A informs that SYSTEMAIR SDN BHD carried out the following tests for AWP cabinet range models with CMP motors.

Test Standard: EN 12101-3:2015

Model	File N°	Test date	Power	Tension/frequency
AWP 550 cabinet	19/19576-1698	01/10/19	5,5 kW	400V/50 Hz
AWP 750 cabinet	19/19576-1700	02/10/19	11 kW	400V/50 Hz
AWP 1100 cabinet	19/19576-1701	03/10/19	22 kW	400V/50 Hz

Classification according to EN 13501-4:

F₃₀₀ 60

The fans were tested during 120 minutes without causing any failure.

Sincerely

David Espinosa Amoretti
Fire resistance technician

This document is merely for informational purposes.

The results concern solely and exclusively with the tested samples at the moment and the indicated conditions.

The valid documents are the respective test and range reports completed and emitted by Applus- LGAI.

The results specified here are provisional and subject to possible changes to official test report.